

CLIENT AND LOCATION DETAILS

Client:	Rowney Green Peace Memorial Hall	Location:	As Client
Address:	Rowney Green Lane, Rowney Green, Alvechurch, Birmingham. B48 7QP	Address:	As Client


TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
A21	Fracino Coffee Machine	24.5.17	1	230	PASS	0.05	445							PASS
A22	Display Fridge	24.5.17	1	230	PASS	0.05	999							PASS
A23	Normal Fridge	24.5.17	1	230	PASS	0.05	999							PASS
A24	Glass Washer	24.5.17	1	230	PASS	0.01	106							PASS
A25	Intempo Music Player	24.5.17	2	230	PASS	N/A	999							PASS
A15	Table lamp	24.5.17	1	230	PASS	0.12	999							PASS
A16	Table lamp	24.5.17	2	230	PASS	N/A	999							PASS
A26	Standard Lamp	24.5.17	1	230	FAIL									FAIL
A27	Fairy Lights	24.5.17	2	230	PASS	N/A	999							PASS
A38	Fairy Lights	24.5.17	1	230	PASS									PASS
A39	Fairy Lights	24.5.17	2	230	PASS	N/A	999							PASS
A40	Fairy Lights	24.5.17	1	230	PASS									PASS
A42	Multiblock Extension	24.5.17	1	230	PASS	0.14	999							PASS
A43	Fairy Lights	24.5.17	2	230	PASS	N/A	999							PASS
A44	Fairy Lights	24.5.17	2	230	PASS	N/A	999							PASS
A45	Multiblock Extension	24.5.17	1	230	PASS	0.01	999							PASS
A46	Fairy Lights	24.5.17	1	230	PASS									PASS
A47	Multiblock Extension	24.5.17	1	230	FAIL									FAIL
A48	Multiblock Extension	24.5.17	1	230	FAIL									FAIL
A49	Multiblock Extension	24.5.17	1	230	PASS	0.29	999							PASS
A50	New Acme Fresnel	24.5.17	1	230	PASS	0.01	999							PASS
A52	New Acme Fresnel	24.5.17	1	230	PASS	0.01	999							PASS
A53	New Acme Fresnel	24.5.17	1	230	PASS	0.01	999							PASS
A54	New Acme Fresnel	24.5.17	1	230	PASS	0.01	999							PASS
A55	New Acme Fresnel	24.5.17	1	230	PASS	0.01	999							PASS
A56	New Acme Fresnel	24.5.17	1	230	PASS	0.01	999							PASS
A57	New Acme Fresnel	24.5.17	1	230	PASS	0.01	999							PASS
A58	New Acme Fresnel	24.5.17	1	230	PASS	0.11	999							PASS
A59	New Acme Fresnel	24.5.17	1	230	PASS	0.06	999							PASS
A60	Refurb Strand Spot	24.5.17	1	230	PASS	0.02	999							PASS
A61	Refurb Strand Spot	24.5.17	1	230	PASS	0.11	999							PASS

CONTRACTOR DETAILS

Company:	Paul Chadderton Electrical	Engineer Name:	Paul Chadderton
Address:	5, Granby Close, Redditch, Worcestershire, B98 0PJ	Qualifications:	C & G 2377
		Position:	Owner

Signature:



CLIENT AND LOCATION DETAILS

Client: Rowney Green Peace Memorial Hall
Address: Rowney Green Lane,
Rowney Green,
Alvechurch,
Birmingham.
B48 7QP

Location: As Client
Address: As Client

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD SI	Status
A62	Refurb Strand Spot	24.5.17	1	230	PASS	0.02	999							PASS
A63	Refurb Strand Spot	24.5.17	1	230	PASS	0.05	999							PASS
A174	600mm Trailing Lead	24.5.17	1	230	PASS	0.01	999							PASS
A118	Mirror Ball Disc	24.5.17	1	230	PASS	0.09	999							PASS
A119	Mirror Ball Light	24.5.17	1	230	PASS	0.01	999							PASS
A120	Mirror Ball Light	24.5.17	1	230	PASS	0.01	999							PASS
A121	Mirror Ball Light	24.5.17	1	230	PASS	0.01	999							PASS
-----	END OF RESULTS	-----				-----	-----							

CONTRACTOR DETAILS

Company: Paul Chadderton Electrical
Address: 5, Granby Close,
Redditch,
Worcestershire.
B98 0PJ

Engineer Name: Paul Chadderton
Qualifications: C & G 2377
Position: Owner

Signature: *Paul Chadderton*

CLIENT AND LOCATION DETAILS

Client:	Rowney Green Peace Memorial Hall	Location:	As Client
Address:	Rowney Green Lane, Rowney Green, Alvechurch, Birmingham. B48 7QP	Address:	As Client

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
A4	Microwave Oven	24.5.17	1	230	PASS	0.06	999							PASS
A5	Fridge	24.5.17	1	230	PASS	0.11	999							PASS
A6	Water Heater	24.5.17	1	230	PASS	0.21	830							PASS
A7	Kettle	24.5.17	1	230	PASS	0.06	130							PASS
A33	Fairy lights transformer	24.5.17	2	230	PASS	N/A	999							PASS
A34	Fairy lightstransformer	24.5.17	2	230	PASS	N/A	999							PASS
A35	Fairy lights timer	24.5.17	2	230	PASS	N/A	999							PASS
A36	Fairy lights transformer	24.5.17	2	230	FAIL	N/A	999							FAIL
A165a	Portable radio	24.5.17	2	230	PASS	N/A	999							PASS
A8	Kettle	24.5.17	1	230	PASS	0.04	999							PASS
A170	Beer chiller	24.5.17	1	230	PASS	0.03	999							PASS
A171	Beer chiller	24.5.17	1	230	PASS	0.02	283							PASS
A9	Henrietta Vacuum	24.5.17	2	230	PASS	N/A	999							PASS
A10	Dyson Vacuum	24.5.17	2	230	PASS	N/A	999							PASS
A31	Echo Hostess	24.5.17	1	230	PASS	0.12	16.6							PASS
A11	16A plug to twin 13A sockets	24.5.17	1	230	PASS	0.01	999							PASS
A17	16A 3 way splitter	24.5.17	1	230	PASS	0.01	999							PASS
A166	Slow Cooker	24.5.17	1	230	PASS	0.06	830							PASS
A167	Slow Cooker	24.5.17	1	230	PASS	0.03	999							PASS
A168	Slow Cooker	24.5.17	1	230	PASS	0.08	999							PASS
A169	Slow Cooker - NOT FOUND													
A172	Spare beer chiller	24.5.17	1	230	PASS	0.11	438							PASS
A173	15m 10A Extension lead	24.5.17	1	230	PASS	0.27	999							PASS
A128	Desk lamp	24.5.17	2	230	PASS	N/A	999							PASS
A126	Amplifier	24.5.17	1	230	PASS	0.06	739							PASS
A125	Fold back speakers	24.5.17	1	230	PASS	0.28	999							PASS
A123	Digital Projector	24.5.17	1	230	PASS	0.04	779							PASS
A129	Lead for Projector	24.5.17	1	230	PASS	0.04	999							PASS
A130	Projector Screen controller	24.5.17	2	230	PASS	N/A	263							PASS
A165	Multi block Extension	24.5.17	1	230	PASS	0.01	999							PASS
BLANK	BLANK													

CONTRACTOR DETAILS

Company:	Paul Chadderton Electrical	Engineer Name:	Paul Chadderton
Address:	5, Granby Close, Redditch, Worcestershire. B98 0PJ	Qualifications:	C & G 2377
		Position:	Owner
		Signature:	<i>P Chadderton</i>