

Asset ID	Type Code	Asset Description	Asset Location	Last Tested	Next Test	Test Freq	Freq Unit	Op Volts	Fuse Rating	Earth Bond Ohms	Ins Meg Ohm	VA	Leak mA	Lead Cond	Result
A10	SC2	DYSON VACUUM	JANITORIAL	20150218	20160218	12	M	230	13	-	>50	1.412	0	-	Pass
A102	SC1	EFFECTS PROJECTOR	LIGHT LOFT	20150218	20170218	24	M	230	13	0.199	>50	0.428	0	-	Pass
A105	SC1	BUBBLE GENERATOR	SOCIALROOM	20150218	20170218	24	M	230	13	0.053	>50	0.035	0	-	Pass
A106	PC	MIXING DESK	LIGHT LOFT	20150218	20170218	24	M	230	13	0.264	-	0	0	-	Pass
A110	SC1	MAIN HALL AMP	LIGHT LOFT	20150218	20170218	24	M	230	5	0.062	>50	0.036	0	-	Pass
A113	SC2	WIRELESS MIC	LIGHT LOFT	20150218	20170218	24	M	230	-	-	>50	0	0	-	Pass
A114	SC2	VIDEO LINK	LIGHT LOFT	20150218	20170218	24	M	230	-	-	>50	0	0	-	Pass
A123	SC2	DIGITAL PROJECTOR	STAGE	20150218	20170218	24	M	230	5	-	>50	0.022	0.29	-	Pass
A127	SC2	DESK LAMP	STAGE	20150218	20170218	24	M	230	3	-	>50	0.021	0	-	Pass
A128	SC1	DESK LIGHT	STAGE	20150218	20170218	24	M	230	3	-	>50	0.022	0	-	Pass
A129	EL1	MULTIBLOC EXTN	STAGE	20150218	20170218	24	M	230	13	0.107	>50	-	-	OK	Pass
A166	SC1	WALL MOUNT DELL VDU	LIGHT LOFT	20150218	20170218	24	M	230	3	0.085	>50	0.018	0.49	-	Pass
A167	VIS	RADIO RECEIVER	LIGHT LOFT	20150218	20170218	24	M	230	-	-	-	-	-	-	Pass
A168	VIS	RADIO RECEIVER	LIGHT LOFT	20150218	20170218	24	M	230	-	-	-	-	-	-	Pass
A20	SC2	DISPLAY SCREEN	SOCIALROOM	20150218	20160218	12	M	230	3	-	>50	0	0	-	Pass
A21	SC1	FRACINO	SOCIALROOM	20150218	20170218	24	M	230	13	0.067	>50	0	0	-	Pass
A22	SC1	DISPLAY FRIDGE	SOCIALROOM	20150218	20170218	24	M	230	5	0.1	>50	0	0	-	Pass
A23	SC1	NORMAL FRIDGE	SOCIALROOM	20150218	20170218	24	M	230	13	0.101	>50	0	0	-	Pass
A24	SC1	GLASS WASHER	SOCIALROOM	20150218	20170218	24	M	230	13	0.06	>50	2.727	0	-	Pass
A25	SC1	BEER COOLER	SOCIALROOM	20150218	20170218	24	M	230	13	0.144	>50	0.451	0	-	Pass
A31	SC1	ECHO HOSTESS	JANITORIAL	20150218	20160218	12	M	230	5	0.132	3.02	0.407	0.12	-	Pass
A38	SC2	FAIRY LIGHT TRANS	GT LOFT	20150218	20160218	12	M	230	-	-	>50	0	0	-	Pass
A39	SC2	FAIRY LIGHTS TRANS	GT LOFT	20150218	20160218	12	M	230	-	-	>50	0.008	0	-	Pass
A4	SC1	MICROWAVE	MH KITCHEN	20150218	20170218	24	M	230	13	0.059	>50	1.37	0.35	-	Pass
A40	SC2	FAIRY LIGHT TRANS	GT LOFT	20150218	20160218	12	M	230	-	-	>50	0.011	0	-	Pass
A41	SC2	FAIRY LIGHT TRANS	GT LOFT	20150218	20160218	12	M	230	-	-	>50	0.016	0	-	Pass
A42	EL1	MULTIBLOC EXTN	GT LOFT	20150218	20160218	12	M	230	13	0.229	>50	-	-	OK	Pass
A43	SC2	FAIRY LIGHT TRANS	GT LOFT	20150218	20160218	12	M	230	-	-	>50	0.011	0	-	Pass
A44	SC2	FAIRY LIGHT TRANS	GT LOFT	20150218	20160218	12	M	230	-	-	>50	0.022	0	-	Pass
A45	EL1	MULTIBLOC EXTN	GT LOFT	20150218	20160218	12	M	230	13	0.105	>50	-	-	OK	Pass
A46	SC2	FAIRY LIGHT TRANS	GT LOFT	20150218	20160218	12	M	230	-	-	>50	0	0	-	Pass
A47	EL1	MULTIBLOC EXTN	SOCIALROOM	20150218	20170218	24	M	230	13	0.157	>50	-	-	OK	Pass
A48	EL1	MULTIBLOC EXTN	SOCIALROOM	20150218	20170218	24	M	230	13	0.103	>50	-	-	OK	Pass
A49	EL1	MULTIBLOC EXTN	SOCIALROOM	20150218	20160218	12	M	230	13	0.232	>50	-	-	OK	Pass
A5	SC1	FRIDGE	MH KITCHEN	20150218	20160218	12	M	230	13	0.106	>50	0	0	-	Pass
A51	SC1	FRESNAL SPOT	LIGHT RAIL	20150218	20180218	36	M	230	-	0.83	>50	0.505	0	-	Pass

A64	SC1	FRESNAL STRAND SPOT	STAGE	20150218	20170218	24	M	230	-	0.084	>50	0.472	0	-	Pass
A65	SC1	FRESNAL PROFILE SPOT	STAGE	20150218	20170218	24	M	230	-	0.12	>50	0.468	0	-	Pass
A66	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.083	>50	0.463	0	-	Pass
A7	SC1	KETTLE	MH KITCHEN	20150218	20160218	12	M	230	-	0.065	>50	2.816	0	-	Pass
A71	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.082	>50	0.476	0	-	Pass
A72	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.077	>50	0.447	0	-	Pass
A73	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.093	>50	0.497	0	-	Pass
A74	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.095	>50	0.471	0	-	Pass
A75	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.079	>50	0.484	0	-	Pass
A76	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.166	>50	0.473	0	-	Pass
A77	SC1	FRESNAL SPOT	STAGE	20150218	20170218	24	M	230	-	0.087	>50	0.497	0	-	Pass
A8	SC1	KETTLE	REAR CORRI	20150218	20160218	12	M	230	-	0.069	>50	2.809	0	-	Pass
A80	SC1	STRAND FRESNEL SPOT	STAGE	20150218	20170218	24	M	230	-	0.088	>50	0.489	0	-	Pass
A81	SC1	FRESNAL STRAND SPOT	STAGE	20150218	20170218	24	M	230	-	0.154	>50	0.505	0	-	Pass
A82	SC1	FRESNAL STRAND SPOT	STAGE	20150218	20170218	24	M	230	-	0.134	>50	0.497	0	-	Pass
A83	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.082	>50	0.477	0	-	Pass
A84	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.078	>50	0.473	0	-	Pass
A85	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.081	>50	0.478	0	-	Pass
A86	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.092	>50	0.48	0	-	Pass
A87	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.087	>50	0.471	0	-	Pass
A88	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.092	>50	0.474	0	-	Pass
A89	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.106	>50	0.471	0	-	Pass
A9	SC2	HENRY VACUUM	JANITORIAL	20150218	20160218	12	M	230	13 -		>50	1.028	0	-	Pass
A90	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.104	>50	0.465	0	-	Pass
A91	SC1	COMP BATTEN SPOT	STAGE	20150218	20170218	24	M	230	-	0.106	>50	0.481	0	-	Pass