

Asset ID	Type Code	Asset Description	Asset Location	Last Tested	Next Test	Test Freq	Freq Unit	Op Volts	Fuse Rating	Earth Bond Ohms	Ins Meg Ohm	VA	Leak mA	Lead Cond	Result
A50	SC1	BOX SPOT	LIGHT LOFT	20131106	20161106	36	M	230	-	0.067	>50	0.538	0	-	Pass
A100	SC1	UV LIGHT	LIGHT LOFT	20131106	20151106	24	M	230	13	0.097	>50	0.966	0	-	Pass
A101	SC2	BIFOCAL SPOT	LIGHT LOFT	20131106	20161106	36	M	230	3	-	>50	0.047	0	-	Pass
A103	SC1	SMOKE MACHINE	LIGHT LOFT	20131106	20151106	24	M	230	13	0.097	26.67	0.691	0	-	Pass
A104	SC1	NEON SMOKE MACHINE	LIGHT LOFT	20131106	20151106	24	M	230	-	0.1	32.69	0.4	0	-	Pass
A107	PC	EVESHAM PC	LIGHT LOFT	20131106	20161106	36	M	230	3	0.071	-	0	0.49	-	Pass
A108	SC1	DESKTOP DELL VDU	LIGHT LOFT	20131106	20151106	24	M	230	3	>10	>50	0.021	0.48	-	Pass
A109	SC2	LIGHT CONTROL PSU	LIGHT LOFT	20131106	20151106	24	M	230	3	-	>50	0	0.17	-	Pass
A112	SC1	DESK LAMP	LIGHT LOFT	20131106	20151106	24	M	230	3	0.095	>50	0.043	0	-	Pass
A115	SC1	FAN	LIGHT LOFT	20131106	20151106	24	M	230	13	0.097	>50	0.138	0	-	Pass
A116	SC1	SOLDERING IRON	LIGHT LOFT	20131106	20151106	24	M	230	-	0.305	-	-	-	-	Fail
A117	SC1	PORT DIMMER	LIGHT LOFT	20131106	20151106	24	M	230	-	0.098	>50	0	0.17	-	Pass
A118	SC1	MIRROR BALL DISC 1	LIGHT RAIL	20131106	20161106	36	M	230	-	0.1	>50	0	0	-	Pass
A119	SC1	MIRROR BALL LGHT 1	LIGHT RAIL	20131106	20161106	36	M	230	-	0.1	>50	0.04	0	-	Pass
A120	SC1	MIRROR BALL LGHT 2	LIGHT RAIL	20131106	20161106	36	M	230	-	0.073	>50	0.038	0	-	Pass
A121	SC1	MIRROR BALL DISC 2	LIGHT RAIL	20131106	20161106	36	M	230	-	0.098	>50	0.038	0	-	Pass
A122	VIS	WIRELESS CAMERA	LIGHT RAIL	20131106	20161106	36	M	230	-	-	-	-	-	-	Pass
A130	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.2	>50	-	-	OK	Pass
A131	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.193	>50	-	-	OK	Pass
A132	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.225	>50	-	-	OK	Pass
A133	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.239	>50	-	-	OK	Pass
A134	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.205	>50	-	-	OK	Pass
A135	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.203	>50	-	-	OK	Pass
A136	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.193	>50	-	-	OK	Pass
A137	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.148	>50	-	-	OK	Pass
A138	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.182	>50	-	-	OK	Pass
A139	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.088	>50	-	-	OK	Pass
A140	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.171	>50	-	-	OK	Pass
A141	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.189	>50	-	-	OK	Pass
A142	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.373	>50	-	-	OK	Pass
A143	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.147	>50	-	-	OK	Pass
A144	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.148	>50	-	-	OK	Pass
A145	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.183	>50	-	-	OK	Pass

Asset ID	Type Code	Asset Description	Asset Location	Last Tested	Next Test	Test Freq	Freq Unit	Op Volts	Fuse Rating	Earth Bond Ohms	Ins Meg Ohm	VA	Leak mA	Lead Cond	Result
A146	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.217	>50	-	-	OK	Pass
A147	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.126	>50	-	-	OK	Pass
A148	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.093	>50	-	-	OK	Pass
A149	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.117	>50	-	-	OK	Pass
A150	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.092	>50	-	-	OK	Pass
A151	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.095	>50	-	-	OK	Pass
A152	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.089	>50	-	-	OK	Pass
A153	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.095	>50	-	-	OK	Pass
A154	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.225	>50	-	-	OK	Pass
A155	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.129	>50	-	-	OK	Pass
A156	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.19	>50	-	-	OK	Pass
A157	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.133	>50	-	-	OK	Pass
A158	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.293	>50	-	-	OK	Pass
A159	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.188	>50	-	-	OK	Pass
A160	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.335	>50	-	-	OK	Pass
A161	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.247	>50	Repaired	-	OK	Pass
A161	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	-	-	-	-	Transposed	Fail
A162	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.125	>50	-	-	OK	Pass
A163	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	13	0.232	>50	-	-	OK	Pass
A164	EL1	TRAILING LEAD	LIGHT LOFT	20131106	20151106	24	M	230	-	0.218	>50	-	-	OK	Pass
A165	EL1	EXTN CABLE REEL	LIGHT LOFT	20131106	20151106	24	M	230	13	0.442	>50	-	-	OK	Pass
A166	SC1	WALL MOUNT DELL VDU	LIGHT LOFT	20131106	20151106	24	M	230	3	0.069	>50	0	0.46	-	Pass
A51	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	>10	-	-	-	-	Fail
A52	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.069	>50	0.544	0	-	Pass
A53	SC1	FRESNAL SPOT	LIGHT LOFT	20131106	20161106	36	M	230	-	0.07	>50	0.544	0	-	Pass
A54	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.067	>50	0.526	0	-	Pass
A55	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.072	>50	0.543	0	-	Pass
A56	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.064	>50	0.543	0	-	Pass
A57	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.067	>50	0.53	0	-	Pass
A58	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.072	>50	0.542	0	-	Pass
A59	SC1	FRESNAL SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.068	>50	0.546	0	-	Pass
A60	SC1	PROFILE LAMP	LIGHT RAIL	20131106	20161106	36	M	230	-	0.079	>50	0.448	0	-	Pass
A61	SC1	PROFILE SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.073	>50	0.484	0	-	Pass

Asset ID	Type Code	Asset Description	Asset Location	Last Tested	Next Test	Test Freq	Freq Unit	Op Volts	Fuse Rating	Earth Bond Ohms	Ins Meg Ohm	VA	Leak mA	Lead Cond	Result
A62	SC1	PROFILE SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.089	>50	0.467	0	-	Pass
A63	SC1	PROFILE SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.084	>50	0.486	0	-	Pass
A67	SC1	PROFILE SPOT	LIGHT LOFT	20131106	20161106	36	M	230	-	0.098	>50	0.494	0	-	Pass
A68	SC1	PROFILE SPOT	LIGHT LOFT	20131106	20161106	36	M	230	-	0.07	>50	0.458	0	-	Pass
A69	SC1	PROFILE SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.086	>50	0.474	0	-	Pass
A70	SC1	PROFILE SPOT	LIGHT RAIL	20131106	20161106	36	M	230	-	0.078	>50	0.491	0	-	Pass
A78	SC1	FRESNAL SPOT	LIGHT LOFT	20131106	20161106	36	M	230	-	0.076	>50	0.482	0	-	Pass
A79	SC1	FRESNAL SPOT	LIGHT LOFT	20131106	20161106	36	M	230	-	0.081	>50	0.494	0	-	Pass